

ACCOUSTIC CEILING TILE

ALTERNATE

ALUMINUM

ANCHOR BOLT

ARCHITECTURAL

AT OR AT THE

BLOCK

BLOCKING

BOARD

BOTTOM

BUILDING

CARPET

CAULKING

CAST IRON

CEILING

CEMENT

CENTER

CERAMIC

CLOSET

COLUMN

CONCRETE

CONNECTION

CONSTRUCTION

CONTRACTOR

CONTROL JOINT

CORRIDOR

COUNTER

DETAIL

DOWN

EAST

EACH

ELECTRIC (AL)

COUNTERSUNK

DEPARTMENT

DIAMETER

DIMENSION

DOWNSPOUT

DRINKING FOUNTAIN

DRAWING

CONCRETE MASONRY UNIT

CORRUGATED METAL PIPE

CONTINUE/CONTINUOUS

CENTER LINE

CERAMIC TILE

CLEAR (ANCE)

ALUM.

ARCH.

BLKG.

BLDG.

CMP

CONN.

CONSTR

CONT.

CONTR.

CNTR.

CTSK.

DWG.

ELEC.

ELEV./EL.

EXISTING

EQUIPMENT

EXISTING

EXPANSION

FIRE ALARM

F.E. CABINET

FLOOR DRAIN

FACE OF STUD

FACE OF WALL

FOUNDATION

FINISH FLOOR

GALVANIZED

GAUGE

GLASS

GRADE

GROUND

GALVANIZED IRON

GYPSUM BOARD

HARDWARE GROUP #

HARDWOOD

HIGH POINT

HORIZONTAL

HOLLOW METAL

HOURS (FIRE RATING)

INSIDE DIAMETER

INVERT ELEVATION

JUNCTION BOX

INSULATION

INTERIOR

JANITOR

KITCHEN

LAMINATE

LAVATORY

LOW POINT

LIGHT

JOINT

HOSE BIBB

HEIGHT

GYPSUM WATERPROOF BOARD

HIGH DENSITY POLYETHYLENE

FOOTING

FLOOR

FIRE EXTINGUISER

EXTERIOR

EQUAL

EQUIP.

F.A.

F.E.C.

F.O.W.

FDN.

GND.

GYP. BD.

H.D.P.E.

MATERIAL

MASONRY

MANHOLE

MAXIMUM

MECHANICAL

MEN'S TOILET

MISCELLANEOUS

NOT IN CONTRACT

ORDINATE NUMBER

NOT TO SCALE

MEMBRANE

METAL

MINIMUM

MIRROR

MOUNTED

MULLION

NOMINAL

NORTH

NUMBER

OFFICE

ON CENTER

OPENING

OPPOSITE

OPPOSITE HAND

PAINTED EPOXY

PAINTED

PARTITION

PLASTER

PLATE

PLYW00D

RADIUS

REFLECTED

REQUIRED

REINFORCING

QUARRY TILE

RUBBER BASE

RAIN WATER LEADER

REFERENCE FINISH FLOOR

POINT

PEDESTRIAN

PLASTIC LAMINATE

PAIR

OUTSIDE DIAMETER

OVERFLOW ROOF DRAIN

MAINT.

MFR.

М.Н.

M.O.

MAX.

MECH.

МЕМВ.

MTL./MET.

MEN

MISC.

MTD.

NOM.

N.T.S.

OR#

OPNG.

OPP. H.

0.R.D.

PTD. -E

PART.

PLAS.

P. LAM.

PLYWD.

RAD.

R.B.

R.W.L.

R.F.F.

REINF.

MAINTENANCE

MANUFACTURER

MASONRY OPENING

RETAINING

ROOF DRAIN

SCHEDULE

SEALANT

SERVICE SINK

SOLID CORE

SQUARE

STEEL

STORAGE

SYMMETRICAL

TO BE REMOVED

TELEPHONE

THICK (NESS)

TOP OF CURB

TOP OF PLATE

TOP OF WALL

UNFINISHED

VERTICAL

WITH

WOOD

WATERPROOF

WORKING POINT

WATER RESISTANT

FENCE

WROUGHT IRON

WAINSCOT

WITHOUT

VARY OR VARIES

VENT THROUGH ROOF

VINYL COMPOSITION TILE

WELDED ANCHOR STUD

UNLESS NOTED OTHERWISE

TREAD

TYPICAL

TOP OF FOOTING

STANDARD

SPECIFICATIONS

STRUCTURAL/STRUCTURE

TEMPORARY / TEMPERED

TONGUE AND GROOVE

TOP OF CONCRETE

SECTION

SHEET

SIMILAR

SLOPE

ROUGH OPENING

REVISED

RISER

ROOM

REV.

R.D.

R.O.

SCHED.

SEAL.

SL./SLP.

STD.

STOR.

SYM.

T.B.R.

TEMP.

T&G

T/CONC

T/CURB

T.O. FTG.

U.N.O.

VERT.

V.T.R.

W.A.S.

STRUCT

# STORES & RECEIVING BUILDING **EXPANSION / RENOVATION PHASE 2** Weber State University



DIVISION OF FACILITIES CONSTRUCTION AND MANAGEMENT

## **HFS**Architects

Salt Lake City, Utah 8411

DESCRIPTION

28 DECEMBER 2006

ARCHITECTURAL


05276810

0528.02

RLS

**BWS** 

RLS





d) Means or Egress Analysis. e) Fire Assembly Locator Sheet.


TO REMOVE


f) Exterior and Interior Accessibility Route.


g) Fire Stopping, Including Tested Design Number.












#### LEGEND OF MECHANICAL SYMBOLS AND ABBREVIATIONS **PLUMBING MECHANICAL** PLUMBING CONT. LINETYPES LINETYPES CONT REVERSE OSMOSIS WATER SUPPLY ACID VENT POSITIVE PRESSURE DUCT - RISE FLOOR SINK HOSE BIBB REVERSE OSMOSIS WATER RETURN FLOOR DRAIN PIPE CAP \_\_\_\_\_ROR\_\_\_\_ POSITIVE PRESSURE DUCT - DROP <del>----</del> ———AW——— WASTE FLOOR CLEAN-OUT NEGATIVE PRESSURE DUCT - RISE BOILER BLOW SWITCH ——BBD—— -----RD-----OR CLEAN-OUT TO GRADE **SENSOR** NEGATIVE PRESSURE DUCT - DROP ROOF DRAIN BOILER FEED WATER -----RDO-----ROOF DRAIN OVERFLOW REFRIGERANT LIQUID DOWNSPOUT NOZZLE THERMOSTAT ------RL------ROUND DUCT - RISE CARBON DIOXIDE ARROW INDICATES DIRECTION OF FLOW IN ROUND DUCT - DROP \_\_\_\_C02\_\_\_\_ -----RS----**NIGHT THERMOSTAT** REFRIGERANT ΦN SUCTION COMPRESSED AIR UNDER FLOOR DUCT **─**□ \_\_\_\_\_CA\_\_\_\_ CHECK VALVE SEWER (BELOW GRADE) PRESSURE REDUCING, EXTERNAL PRESSURE DRAIN PAN AND P-TRAP ——CF—— **CHEMICAL** SEWER (ABOVE TURNING VANES GRADE) (NAME) SOFT DOMESTIC WATER **——** FIXTURE FROM LEVEL ABOVE \_\_\_\_\_SW\_\_\_\_ PRESSURE REDUCING, SELF CONTAINED ——CHWS—— CHILLED WATER SUPPLY **A**RCHITECTURE FRESH AIR LOUVER VALVE **──☆** ATC VALVE - 2 WAY GPM<sub>1</sub>: LB/HR. ——CHWR—— CHILLED WATER RETURN \_\_\_\_\_V\_\_\_\_ FLOW METER ORIFICE **I**NTERIORS **P**LANNING ATC VALVE - 3 WAY VENT (SEWER) CONDENSER WATER SUPPLY RELIEF AIR OR EXHAUST AIR LOUVER 1484 South State Street SOLENOID 90° ELBOW CONDENSER WATER RETURN Salt Lake City, Utah 84115 801-596-0691/F: 596-0693 $\longrightarrow$ CEILING SUPPLY DIFFUSER GATE VALVE DOMESTIC COLD WATER 45° ELBOW www.hfsa.com STEAM TRAP, F&T=FLOAT & THERMOSTATIC B=BUCKET, T=THERMOSTATIC CONSULTANT CEILING RETURN REGISTER GATE VALVE - NON RISING STEM DOMESTIC HOT WATER (DHW) CEILING EXHAUST REGISTER, (BALANCE TO MATCH SUPPLY $\longrightarrow$ LEADER INDICATES DOWNWARD DOMESTIC HOT WATER RETURN GLOBE VALVE RETURN CFM IS NOT SHOWN) TOP FIGURES INDICATE SIDEWALL SUPPLY VAN BOERUM NECK SIZE. BOTTOM TEMPERATURE AND PRESSURE TEST DEIONIZED WATER SUPPLY —— DI —— $-\times \times$ \_\_\_\_\_ DEMOLITION REGISTER FIGURE INDICATES CFM. & FRANK ASSOCIATES INC SIDEWALL EXHAUST OR PRESSURE SWITCH ALIGNMENT GUIDE \_\_\_\_ DEIONIZED WATER RETURN ——DIR—— RETURN REGISTER NWW.VBFA.COM CONSULTING ENGINEERS 330 South 300 East 1620 W Fountainhead Pkwy 1704 W Sunset blvd #3 CEILING SUPPLY DIFFUSER Salt Lake City, UT 84111 Tempe, AZ 85282 GAS COCK ——E(NAME)—— **EXISTING PIPING** WITH FLEXIBLE DUCT 801.530.3148 T 480 889 5075 T 435.674.2708 T 801.530.3150 F 435.674.4800 F 480.889.5076 F CEILING AIR GRILLE WITH 0.0 GPM CALIBRATED BALANCING $\longrightarrow$ (NAME) $\longrightarrow$ EXISTING PIPING TO BE FLEXIBLE DUCT VALVE WITH GPM INDICATED REMOVED CEILING RETURN AIR GRILE **RPBP** FLOW CONTROL -----GHR-----GLYCOL HEAT RECOVERY PIPING W/ SOUND BOOT 3-1" SLOTS LINEAR DIFFUSER WITH PLENUM AND FLEXIBLE DUCT 3-1" SLOTS LINEAR DIFFUSER WITH PLENUM AND FLEXIBLE DUCT CONNECTION. NO. OF SLOTS & SIZE OF SLOT ON TOP, BRANCH - BOTTOM CONNECTION ——G(NAME)—— **GLYCOL PIPING SOLUTION** ACTIVE LENGTH AND CFM ON BOTTOM BRANCH - TOP CONNECTION ——FOR—— FUEL OIL No. 5484 FLEXIBLE DUCT CONNECTION RETURN **SYMBOLS** NEIL H. BRANCH - SIDE CONNECTION FUEL OIL SUPPLY SPENCER ——F0S—— FLEXIBLE DUCT <u>P-1</u>/ FIXTURES RISE OR DROP FUEL OIL VENT ——F0V—— POINT OF CONNECTION FLAT OVAL DUCT WITH NET INSIDE 12/8 F0 RISER - DOWN (ELBOW) NATURAL GAS DIMENSIONS SHOWN IN INCHES. STORES & RECEIVING RECTANGULAR DUCT WITH NET INSIDE 12/8 SECTION TAG - TOP FIGURE IS SECTION NO. ——HG—— RISER - DOWN (ELBOW) DIMENSIONS SHOWN IN INCHES. BOTTOM FIGURE IS SHEET NO. **EXPANSION / RENOVATION** ROUND DUCT WITH NET INSIDE DIMENSIONS VENT THRU ROOF ——HFR—— HELICOPTER FUEL RETURN 12ø OVTR SHOWN IN INCHES. PHASE 2 Α DETAIL TAG - TOP FIGURE IS DETAIL NO. <u>UP</u> WATER HAMMER ARRESTOR HELICOPTER FUEL ——HFS—— INCLINED RISE WITH RESPECT TO AIR FLOW 15° BOTTOM FIGURE IS SHEET NO. M101 SUPPLY - NOMINAL INCLINE WITH RADIUS $-\!\!\!\!-\!\!\!\!\!-\!\!\!\!\!-\!\!\!\!\!\!-$ TURNS=DEPTH OF DUCT. HIGH PRESSURE DOMESTIC Weber State University INLINE PUMP INCLINED DROP ——HP(NAME)— EQUIPMENT IDENTIFICATION Ogden, Utah w R R/W=1. ROUND DUCT SIMILAR TO RECTANGULAR INLINE PUMP HIGH PRESSURE ——HPC—— CONDENSATE KEYED NOTE IDENTIFICATION RECTANGULAR TO RECTANGULAR OR ROUND TO ROUND 12/12 8/8 } CLEAN-OUT DUCT TRANSFORMATION MAXIMUM 15° INCLUDED ANGLE ——HPS—— HIGH PRESSURE EXCEPT WHERE SHOWN OTHERWISE. STEAM PROPERTY ID#: 4016 12/12 120 HEATING HOT WATER RETURN RELIEF VALVE ——HWR—— RECTANGULAR TO ROUND DUCT TRANSFORMATION BRANCH DUCT SPLIT WITH 6" WIDTH AND MIN. R R=WIDTH OF BRANCH DUCT DOWNSTREAM. ANGLE VALVE ——HWS—— HEATING HOT WATER DESCRIPTION MARK DATE ELBOW TURNING VANE OPTIONAL. SUPPLY INSTRUMENT AIR TAP ENTRY AREA EQUALS 150% OF BRANCH AREA **─** FLOW METER INSTRUMENT AIR AT PRESSURE HIGH EFFICIENCY FITTING ——IA 120—— <u>FIRE</u> MANUAL VOLUME DAMPER **─**─Ĩ── BALANCING COCK VALVE SHUT-OFF COCK FOR USE WITH PRESSURE FIRE DAMPER IN DUCT, W/ ACCESS PANEL REQD. \_\_\_\_LV\_\_\_\_ NRS GATE VALVE WITH SUPERVISION FLEXIBLE EXPANSION COMBINATION FIRE/SMOKE DAMPER W/ ACCESS PANEL \_\_\_\_ ——LPC —— LOW PRESSURE CONDENSATE FLOW SWITCH DATE: Dec. 28, 2006 ——LPG—— LIQUIFIED PETROLEUM THERMOMETER - TEMP RANGE AS INDICATED SMOKE DAMPER W/ ACCESS PANEL FIRE RISER AGENCY PROJECT NO: 05276810 —\_LPS—\_ LOW PRESSURE STEAM BACK DRAFT DAMPER PRESSURE GAUGE WITH SHUT-OFF COCK HFSA PROJECT NO: 0528.02 **(9)** SPRINKLER HEAD CAD DWG FILE NO: ATCD OR ATC DAMPER MEDICAL AIR PRESSURE GAUGE WITH PIGTAIL ——MA—— DRAWN BY: FIRE SPRINKLER WATER ——F—— LATERAL STRAINER WITH BLOW-OFF VALVE, CHECKED BY: MEDICAL AIR AT PRESSURE PROVIDE HOSE END WITH CAP WHERE DISCHARGE ——MA 120—— ACCESS PANEL IN DUCT OR PLENUM DESIGNED BY: BALL VALVE (PIPE SIZES 2" AND SMALLER) **MECHANICAL** DWG TYPE: HEATING OR COOLING COIL IN DUCT \_\_\_\_MPC\_\_\_\_ MEDIUM PRESSURE BUTTERFLY VALVE (PIPE SIZES 2-1/2" AND CONDENSATE ARCHITECTURAL PHASE: 100% CONSTRUCTION DRAWINGS MOTOR OPERATED BUTTERFLY ——MPS—— MEDIUM PRESSURE CONSTANT VOLUME. MIN. 1-1/2 TERMINAL INLET STEAM SIZE STRAIGHT DUCT AT TERMINAL INLET. SHEET TITLE VALVE IN RISE \_\_\_\_MUW\_\_\_\_ WATER PATTERN FIRST FLOOR HVAC **MEDICAL** \_\_\_\_\_MV\_\_\_\_\_ 3-WAY BLOW VENT-MANUAL PATTERN PLAN NITROGEN \_\_\_\_N\_\_\_ 2-WAY BLOW VENT-AUTO PATTERN FLOW SWITCH NITROUS OXIDE \_\_\_\_\_N20\_\_\_\_ 2-WAY BLOW MEDICAL OXYGEN \_\_\_\_OX\_\_\_\_ REDUCER 1-WAY BLOW PATTERN MEDICAL OXYGEN AT PRESSURE DUCT SMOKE DETECTOR CONCENTRIC REDUCER ——OX 120—— **─** INDICATED ECCENTRIC PUMPED CONDENSATE UNIT HEATER REDUCER SHEET

						PAC	<b>KAGED</b> R	OOFTOP	UNIT SCHE	DULE							
			SUPPLY FAN		HEATING SECTIO	N		COOLING SECTIO	N			FILTER	ELECTRICAL				
				EXTERNAL		ENTERING/			ENTERING	LEAVING				SUPPLY	RELIEF		
			AIRFLOW	STATIC	HEATING	LEAVING		COOLING	AIR TEMP.	AIR TEMP.				FAN	FAN	SINGLE	
			RATE	PRESSURE	LOAD	AIR TEMP.		LOAD	DB/WB	DB/WB			TOTAL	MOTOR	MOTOR	POINT	
ID	MANUFACTURER	MODEL	(CFM)	(IN. WATER)	(BTU/H)	(°F)	MEDIUM	(BTU/H)	(°F)	(°F)	MEDIUM	EFFICIENCY	MCA	(HP)	(HP)	VOLT/PH/HZ	NOTES
RTU-1	AAON	RM-A04	1900	1	76,300	70/105	NAT GAS	43,000	77/62	55/54	DX	30	28	1.5	1	208/3/60	1, 2
RTU-2	AAON	RM-025	8000	1	330,000	70/105	NAT GAS	248,000	85/62	51/50	DX	30	140	5	1	208/3/60	1, 2
																	+

- 1. COMPLETE WITH CENTRIFUGAL POWER RELIEF
- 2. ROOF CURB FURNISHED WITH UNIT

#### **KEYED NOTES**

- 1 34" X 10" RA DUCT UP. SEE SHEET MH102.
- 2 34" X 10" SA DUCT UP. SEE SHEET MH102.
- 3 26" X 10" RA DUCT UP. SEE SHEET MH102.
- 4 26" X 10" SA DUCT UP. SEE SHEET MH102.
- 5 20" X 8" SA DUCT UP. SEE SHEET MH102.
- 6 20" X 8" RA DUCT UP. SEE SHEET MH102. 7 DROP DUCTWORK BELOW BEAM.
- 8 PROVIDE BALANCING DAMPER IN DROP.
- 9 EXHAUST HOOD OVER PRESS. SEE DETAIL.
- BALANCE TO 1260 CFM.




**A**RCHITECTURE INTERIORS **P**LANNING

1484 South State Street Salt Lake City, Utah 84115 801-596-0691/F: 596-0693 www.hfsa.com

CONSULTANT





## STORES & RECEIVING EXPANSION / RENOVATION PHASE 2

Weber State University Ogden, Utah

PROPERTY ID#: 4016

DATE

MARK

EXHAUST DUCT CONNECTION AS HIGH AS POSSIBLE

18 GA. GALVANIZED STEEL HOOD

\_MEZZANINE FLOOR

6'-0" X 6'-0" (FIELD VERIFY)


DESCRIPTION

Dec. 28, 2006
O: 05276810
0528.02
MECHANICAL
SE:
TRUCTION DRAWINGS

SHEET TITLE FIRST FLOOR HVAC

PLAN

SHEET 8 OF 17




FIRST FLOOR HVAC PLAN

SCALE: 1/8" = 1'-0"

\ EXHAUST HOOD DETAIL MH101 SCALE: 1/16" = 1'-0"

DEPTH TO EQUAL BEAM DEPTH ±24"



ROOF CURB FURNISHED WITH ROOFTOP UNIT

— EXISTING STRUCTURE

- FLASH AND COUNTER FLASH ROOF CURB

∕30/36 RA

10/34

ROOFTOP UNIT SECTION


FLASH AND COUNTER FLASH DUCTWORK—

30/36 SA —

30/36 RA-

#### **KEYED NOTES**

- 1 34/10 RA DOWN. SEE SHEET MH101..
- 2 34/10 SA DOWN. SEE SHEET MH101.
- 3 26/10 RA DOWN. SEE SHEET MH101.
- 4 26/10 SA DOWN. SEE SHEET MH101.
- 5 20/8 SA DOWN. SEE SHEET MH101.
- 6 20/8 RA DOWN. SEE SHEET MH101.
- $\overline{7}$  RA DUCT BELOW SUPPLY AIR DUCT.
- $\left\langle 8\right\rangle$  RA BELOW DUCTWORK FROM FROM RTU-1.
- 9 SLOPE DOWN BELOW RA DUCT.
- (10) 24" X 90" RA DUCT UP TO RTU.
- 42" X 64" UP TO RUT ON ROOF. TRANSITION IN CURB AS REQUIRED TO CONNECT TO UNIT.
- 12 14" X 38" RA UP TO RTU UNIT.
- (13) 22" X 38" SA UP TO RTU UNIT.
- 14" X 34" RA UP TO RTU UNIT.
- (15) 20" X 20" SA UP TO RTU UNIT.
- RELOCATE EXISTING GAS FIRED UNIT HEATER AND FLUE THRU ROOF.
- REINSTALL EXISTING GAS FIRED UNIT HEATER AND FLUE THRU ROOF. EXTEND GAS LINE TO NEW HEATER LOCATION.




## **HFS**Architects

**A**RCHITECTURE INTERIORS **P**LANNING

1484 South State Street Salt Lake City, Utah 84115 801-596-0691/F: 596-0693 www.hfsa.com

CONSULTANT





## STORES & RECEIVING EXPANSION / RENOVATION PHASE 2

Weber State University Ogden, Utah

PROPERTY ID#: 4016

MARK	DATE	DESCRIP	TION
DATE:			Dec. 28, 2006
AGENCY	PROJECT	NO:	05276810
HFSA PR	OJECT NO	ı	0528.02
CAD DW	G FILE NO:		
DRAWN	3Y:		
CHECKE	D BY:		
DESIGNE	ED BY:		
DWG TY	PE:		MECHANICAL
	CTURAL PH		N DRAWINGS
SHEET T			
IIDD.	rd r	T AAD	шилс


JUPPER FLOOR HVAC PLAN

9 OF 17 SHEET



		PLUM	BING FIXT	URE SCH	EDULE	
		CW	HW	W	V	
ID	FIXTURE	(IN)	(IN)	(IN)	(IN)	NOTES
S-1	SINK	1/2	1/2	2	1 1/2	COUNTER MOUNTED, SINGLE COMPARTMENT
FH-1	FREEZE-LESS HYDRANT	3/4				

1. ALL UNDER GROUND WASTE AND VENT SHALL BE 2" OR GREATER PER DRAWINGS.



#### **KEYED NOTES**

- 1) 1/2" HW AND CW LINES UP. SEE SHEET PL102.
- 2 CONNECT TO EXISTING 2" GAS LINE.
- 3 DROP PIPING DOWN WALL.
- 4 RUN HW AND CW PIPING BELOW COUNTERTOP TO SINK.
- 5 PROVIDE AIR ADMITTANCE VALVE AT SINK.
- 6 1 1/4" 2 PSIG GAS LINE UP SEE SHEET PL102.
- CONNECT TO EXISTING 4" WASTE LINE. FIELD VERIFY EXACT LOCATION AND ELEVATION OF EXISTING PIPING PRIOR TO STARTING ANY WORK.
- REPLACE EXISTING GAS METER WITH NEW GAS METER.
  ADDITIONAL GAS REQUIREMENT IS 500 CFH. PROVIDE
  CAPACITY FOR FUTURE LOAD OF 500 CFH. PROVIDE 2
  PSIG OUTLET PRESSURE.
- 9 PROVIDE NEW 2 PSIG TO 4 OUNCE GAS PRESSURE REGULATOR IN EXISTING 2" GAS LINE.
- (10) CONNECT TO EXISTING 2" GAS LINE.




## **HFS**Architects

ARCHITECTURE
INTERIORS
PLANNING

1484 South State Street Salt Lake City, Utah 84115 801-596-0691/F: 596-0693 www.hfsa.com

CONSULTANT





## STORES & RECEIVING EXPANSION / RENOVATION PHASE 2

Weber State University
Ogden, Utah

PROPERTY ID#: 4016

		<del>-</del>
MARK	DATE	DESCRIPTION
DATE:		Dec. 28, 2006
AGENCY	PROJECT N	NO: 05276810
HFSA PF	ROJECT NO:	0528.02
CAD DW	G FILE NO:	
DRAWN	BY:	
CHECKE	D BY:	
DESIGNE	ED BY:	
DWG TY	PE:	MECHANICAL
ARCHITE	CTURAL PHA	SE:
100	% CONS	TRUCTION DRAWINGS
SHEET T	TITLE	
	.m ====	

FIRST FLOOR
PLUMBING PLAN

PL101
SHEET 10 OF 17


FIRST FLOOR PLUMBING PLAN

SCALE: 1/8" = 1'-0"

# \_\_\_\_\_ **6** 5 1 1/2" **∞** 7 7 1 1/4" 1 1/4" 2 PSIG GAS LINE DOWN SEE SHEET PL101 UPPER FLOOR PLUMBING PLAN SCALE: 1/8" = 1'-0"

#### **KEYED NOTES**

- GAS LINE UP THROUGH ROOF. PROVIDE SHUT OFF VALVE AND GAS PRESSURE REGULATOR. CONNECT TO ROOFTOP UNIT.
- $\left\langle 2\right\rangle$  1/2" WATER LINES DOWN. SEE SHEET PL102.
- $\overline{3}$  CONNECT TO EXISTING 3/4" PIPING AT WATER HEATER.
- 4 CAP 1" 2 PSIG GAS LINE FOR FUTURE EXTENSION.
- 5 CONNECT NEW 3/4" CW LINE TO EXISTING 1 1/2" CW LINE.
- 6 3/4" UP. TO FREEZELESS HYDRANT AT ROOF.
- 7 RECONNECT BRANCH ROOF DRAIN LINES TO MAIN LINE. FIELD DETERMINE NUMBER AND SIZE OF BRANCH PIPING.
- RELOCATE EXISTING ROOF DRAIN LINE. FIELD VERIFY EXACT SIZE, AND LOCATION. NUMBER OF BRANCH CONNECTIONS ETC. PRIOR TO STARTING ANY WORK.
- 9 CONNECT TO EXISTING ROOF DRAIN PIPING (APPROX. LOCATION).




## **HFS**Architects

ARCHITECTURE
INTERIORS
PLANNING

1484 South State Street Salt Lake City, Utah 84115 801-596-0691/F: 596-0693 www.hfsa.com

CONSULTANT





## STORES & RECEIVING EXPANSION / RENOVATION PHASE 2


Weber State University
Ogden, Utah

PROPERTY ID#: 4016


MARK	DATE	DESCRIPTION
DATE:		Dec. 28, 2006
AGENCY	PROJECT NO	D: 05276810
HFSA PR	OJECT NO:	0528.02
CAD DW	G FILE NO:	
DRAWN E	BY:	
CHECKE	D BY:	
DESIGNE	D BY:	
DWG TYF	PE:	MECHANICAL
	CTURAL PHAS	SE: TRUCTION DRAWINGS
SHEET T	ITLE	

A UPPER FLOOR PLUMBING PLAN

PL102 SHEET 11 OF 17



TYPICAL RECESSED FIXTURE MOUNTING DETAIL




TYPICAL ROUGH-IN REQUIREMENTS DETAIL


N.T.S.

SCALE:

N.T.S.



FIRESTOP FOR METAL CONDUIT THROUGH
N.T.S. GYPSUM WALL BOARD



TYPICAL FIRESTOP FOR CABLES/CONDUIT
THROUGH CONCRETE FLOORING

LIGHTING FIXTURE SCHEDULE SYMBOL DESCRIPTION LAMPS | APPROVED CATALOG NUMBER MANUFACTURERS 8'-0" FLOURESCENT STRIP LIGHT WITH REFLECTOR LITHONIA TC230MVOLT GEBIOIS 2WGCUN CHAIN HANG KIT AND WIRE GUARD. TO MATCH (4) FO30 | COLUMBIA CS8-230-EB8LH-I20-2CSRA4-CSWG4 EXISTING. T-8 METALUX 8TSTN-230-120-TEB81-SNLSYM-WG/SN SW8T232HPF-120-SOHI-2NSYMF48S-AWG3W-CSP SAME AS T-I EXCEPT 4'-0" LITHONIA C23Q MVOLT GEBIOIS WGCUN (2) FO30 | COLUMBIA CSA-230EB8LH-I20-CSRA4-CSWG4 T-8 METALUX STN-230-120-TEB8I-SNLSYM-WG/SN SW4S232HPF-120-SOHI-NSYMF48S-AWG3W-CSP 2' X 4' RECESSED GRID MOUNTED LIGHT FIXTURE LITHONIA 2SP8-G332-Al2l25-I2O-GEBIOIS | WITH FLUSH DOOR AND .125" ACRYLIC PRISMATIC ST824-332G-FSAI2.I25-3EB8LHUNV *CO*LUMBIA (T-2) T-8 METALUX 2GR8-332Al25-l20-EB8I-U XP2GVI332-UNV-H3-PROGRAM START SAME AS T-2 EXCEPT WITH DUAL BALLASTS. 29P8-G332-Al2l25-l2O-(2)GEBIOIS LITHONIA ST824-332G-FSAI2.I25-EB8LHUNV *CO*LUMBIA 3F030 (T-3)T-8 METALUX 2GR8-332Al25-l20-EB82-U XP2GVI332-UNV-HI-PROGRAM (DUAL) GREEN LED EXIT SIGN WITH 90 MINUTE BATTERY LITHONIA LHQM S W 3 G 120/277 RO PACK. DUAL-LITE CV3GEW EX-I INCLUDED SURE LITES LPXH70DGWHDH LOL SAME AS EX-I EXCEPT WITH REMOTE MOUNTED LITHONIA LHQM W3G 120/277 ELANXH0606 EXTERIOR LIGHT. DUAL LITES (EX-IA) INCLUDED SURE LITES LOL

#### NOTES

- ALL FLUORESCENT LIGHTS SHALL HAVE ELECTRONIC PROGRAMMABLE START BALLAST'S, 10%, TOTAL HARMONIC DISTORTION.
  UNIVERSAL, ADVANCE AND SYLVANIA ARE APPROVED MANUFACTURERS. BALLAST'S TO HAVE 5 YEAR WARRANTY.
- 2. ALL FLUORESCENT LAMPS SHALL HAVE 4100° COLOR TEMPERATURE.
- 3. FIELD VERIFY ALL LIGHTING VOLTAGES PRIOR TO PLACING ANY ORDER.
- 4. THE WRITTEN CRITERIA OF THE FIXTURE DESCRIPTION TAKES PRECEDENCE OVER THE CATALOG NUMBER.
- 5. PROVIDE PREMIUM T-8 LAMPS AND BALLAST.

	MECHANICAI	L EQ	UIPM.	IENT	'SC	HED	ULE	
	NAME OF MECHANICAL EQUIPMENT	ROOF TOP UNIT	ROOF TOP UNIT					
	EQUIPMENT NO.	RTU-I	RTU-2			-		
	RATING/WATTS							
	VOLTAGE	208	208			-		
	PHASE	3	3					
	AMPS	20	140					
ATA	WIRE SIZE	3 #8	3 #3/0					
10TOR DATA	GROUND WIRE	1 #10	I #6					
MOTC	CONDUIT SIZE	3/4"	I-I/2"					
_	FUSE DISC. SW.							
	TYPE RKI FUSES							
	NON-FUSE SW.							
	CAPACITOR (KVAR)							
	NOTES	2	2,3					

NOTES:


I. PROVIDE THERMAL OVERLOAD SWITCH.


2. STARTER AND DISCONNECT PROVIDED WITH THE UNIT.


3. PROVIDE DUCT DETECTOR IN RETURN DUCT, AND TIE TO FACP. ALSO TIE THE UNIT TO FACP FOR FAN SHUT DOWN.

	SYMBOL	DESCRIPTION
_	Ф	DUPLEX CONVENIENCE OUTLET - 20 AMP
	•	DUPLEX CONVENIENCE OUTLET - 20 AMP GROUND FAULT INTERRUPTER
	<b>+</b>	4-PLEX CONVENIENCE OUTLET - 20 AMP
	J	JUNCTION BOX - SIZE AND FUNCTION AS REQUIRED
		CONDUITS CONCEALED IN CEILING AND WALLS
		ARROWS INDICATE HOME RUNS
<b>-</b>		FUSED DISCONNECT SWITCH - SIZE AS REQUIRED
	<b>(</b>	MOTOR LOCATION
	\$ <del>1</del>	MANUAL DISCONNECT WITH THERMAL OVERLOAD PROTECTION
		ELECTRICAL PANEL LOCATION
	•	PUSH BUTTON SWITCH
		POWER POLE
	W.P.	
	XX-X	MECHANICAL EQUIPMENT CALLOUT
	$\Diamond$	REFERENCE NOTE CALLOUT
		LIGHTING SYSTEM SYMBOL LIST
	SYMBOL	DESCRIPTION
		SURFACE MOUNTED FLUORESCENT FIXTURE
	E,NL	EMERGENCY NIGHT LIGHT
	<del>                                     </del>	FLUORESCENT STRIP LIGHT FIXTURE
		WALL MOUNTED FIXTURE
	$\otimes$	EXIT LIGHT. ARROWS SHOW EXIT DIRECTION
		WALL MOUNTED LIGHT FIXTURE
	<u>Q</u>	WALL MOUNTED CAN LIGHT FIXTURE
	\$	SINGLE POLE TOGGLE SWITCH - 20 AMP
	<b>\$</b> a,b	SINGLE POLE TOGGLE SWITCH - 20 AMP, LETTERS INDICATE SWITCH ASSIGNMENT
	\$3	THREE WAY TOGGLE SWITCH - 20 AMP
	\$4	FOUR WAY TOGGLE SWITCH - 20 AMP
	T-X	LIGHTING FIXTURE CALLOUT. NUMBER INDICATES A SUGGESTED QUANTITY- TO BE VERIFIED
	С	OMMUNICATION SYSTEMS SYMBOL LIST
	SYMBOL	DESCRIPTION
		TELEPHONE TERMINAL BOARD
	<b>A</b>	FLUSH TELE/DATA OUTLET BY TELECOMMINICATIONS CONTRACTOR
		FIRE ALARM SYSTEM SYMBOL LIST
	SYMBOL	DESCRIPTION
	SD	FIRE ALARM SYSTEM PHOTOELECTRIC SMOKE DETECTOR
	<b>(D)</b>	FIRE ALARM PHOTOELECTRIC DUCT DETECTOR
	F	FIRE ALARM MANUAL PULL STATION, +48" A.F.F.
	H);	FIRE ALARM HORN WITH STROBE HIGH DECIBEL, 96" A.F.F.

POWER SYSTEMS SYMBOL LIST







GENERAL NOTES

- IN THE EXISTING SPACES TO BE RENOVATED, THE CONTRACTOR SHALL REMOVE ALL LIGHT FIXTURES, SWITCHES, WIRING, CONDUIT, WIRING DEVICES, FIRE ALARM DEVICES, SPEAKERS, VOLUME CONTROLS, ETC. AS REQUIRED WHETHER OR NOT SHOWN ON THE DRAWINGS. COORDINATE THIS WORK WITH GENERAL CONTRACTOR.
- 2 ALL MATERIALS TO BE REMOVED AND RETURNED TO THE OWNER. MATERIALS WHICH THE OWNER DECIDES NOT TO KEEP SHALL BE SALVAGED AND REMOVED FROM THE SITE BY THE CONTRACTOR.
- 3 ALL CONCEALED CONDUIT THAT CANNOT BE REMOVED SHALL BE CUT FLUSH WITH THE FINISH SURFACES AND CAPPED OFF AFTER THE WIRING HAS BEEN DISCONNECTED AT THE PANEL AND REMOVED FROM THE CONDUIT.
- IN AREAS WHERE CIRCUIT CONTINUITY IS INTERRUPTED, BUT MUST BE MAINTAINED BECAUSE OF THE NATURE OF THE FACILITY, MAKE ALL THE NECESSARY MODIFICATIONS TO THE CIRCUITS IN ORDER TO MAINTAIN THE CIRCUIT INTEGRITY
- 5 THE CONTRACTOR SHALL PATCH THE WALLS AND CEILINGS WHERE THE DEVICES ARE REMOVED TO MATCH THE EXISTING WALLS AND CEILINGS.
- THE COLOR OF ALL THE NEW DEVICES AND COVERPLATES SHALL MATCH THE COLOR OF THE EXISTING DEVICES AND COVERPLATES.
- REFER TO THE ARCHITECTURAL REFLECTED CEILING PLANS FOR THE EXACT LOCATION OF ALL LIGHTING FIXTURES.
- 8 THE COLOR OF THE LIGHT FIXTURES SHALL BE SELECTED BY THE ARCHITECT
  9 MINIMUM SIZE OF CONDUIT TO BE 3/4". ALUMINUM CONDUITS SHALL NOT BE
- USED.

  USE RIGID STEEL SET SCREW TYPE FITTINGS ONLY. DIE CAST FITTINGS SHALL
- NOT BE USED.

  SUPPORT THE LAY-IN TYPE FIXTURES FROM THE CEILING DECK INDEPENDENT OF THE CEILING GRID, AS SHOWN ON THE TYPICAL RECESSED FIXTURE
- MOUNTING DETAIL.

  (1) REFER TO THE MECHANICAL SHEETS FOR THE EXACT LOCATION OF THE
- MECHANICAL EQUIPMENT.

  (13) ALL NEW WORK MUST MEET THE CURRENT ADOPTED NATIONAL ELECTRICAL
- CODE.

  (A) NOT MORE THAN THREE (3) CIRCUITS, SHALL BE INSTALLED IN A CONDUIT.

EACH CIRCUIT SHALL CONSIST OF I CONDUCTOR FOR EACH PHASE, I NEUTRAL

- AND I GROUND, FOR A TOTAL OF FIVE CONDUCTORS.


  THE SIZE OF THE NEUTRAL CONDUCTORS SHALL BE NO. 10 AWG FOR ALL HOME
- RUNS WITH COMMON NEUTRAL (LIGHTING AND POWER CIRCUITS).
- FOR SPECIFICATION OF PULL WIRES IN EMPTY CONDUITS, REFER TO THE ELECTRICAL SPECIFICATION FOR RACEWAYS SECTION 16110.
- THE MINIMUM SIZE OF THE CONDUCTORS ARE TO BE #12 AWG THHN COPPER, UNLESS INDICATED OTHERWISE ON THE DRAWINGS.
- DETAILS ARE SHOWN ON DIFFERENT SHEETS. THE CONTRACTOR SHALL REFER TO THOSE DETAILS WHETHER OR NOT CALLED IN REFERENCE NOTES.
- (19) ALL J-BOXES SHALL HAVE MINIMUM DEPTH OF 2-1/8" UNLESS OTHERWISE SPECIFIED. SECURE ALL J-BOXES AS SHOWN IN THE DETAILS. FURNISH AND
- INSTALL PROPER MUD RINGS.

  ALL NEW EXPOSED CONDUIT MUST RUN AGAINST THE WALLS OR CEILINGS. DO NOT PENDANT MOUNT ANY CONDUIT FROM THE CEILINGS.
- ALL THE HOMERUNS MUST BE ACCESSIBLE. DO NOT CARRY A HOMERUN FROM ONE DEVICE TO ANOTHER WHICH IS TIED TO A SEPARATE HOMERUN INSIDE THE WALL. MARK ON ALL THE J-BOXES THE CIRCUIT NAMES AND NUMBERS. USE NO. IO THHN CONDUCTORS FOR CONDUCTOR LENGTH OVER IOO FEET, NO. 8 THHN OVER 200 FEET, NO. 6 THHN OVER 300 FEET AND NO. 4 THHN OVER 400 FEET LENGTH.
- COORDINATE WITH THE OWNER AND ARCHITECT FOR THE EXACT LOCATION OF THE OUTLETS.
- LIGHT SWITCHES INSTALLED ADJACENT TO EACH OTHER, SHALL BE GANGED TOGETHER WITH ONE PIECE COVERPLATE.
- AT THE END OF THE JOB, PROVIDE BLANK COVER PLATES TO MATCH THE OTHER COVER PLATES FOR ALL J-BOXES WHERE DEVICES HAVE NOT YET
- BEEN INSTALLED.

  3 ALL MATERIALS USED IN THIS INSTALLATION SHALL BE U.L. APPROVED AND
- ALL ELECTRICAL WIRING MUST BE IN CONDUIT (ROMEX AND MC CABLE NOT
- FLEXIBLE CONDUITS CAN ONLY BE USED FOR SHORT RUNS (6' MAXIMUM).
- 28 NO CONDUITS SHALL RUN IN DUCT WORK.
- TEMPORARY ELECTRICAL SERVICE IS TO BE PROVIDED BY THE ELECTRICAL CONTRACTOR AND REMOVED BY THE ELECTRICAL CONTRACTOR.
- PRIOR TO SUBMITTING A BID THE ELECTRICAL CONTRACTOR SHALL INSPECT THE SITE AND INCLUDE IN HIS BID PACKAGE ALL CHARGES DUE TO EXISTING CONDITIONS. SHOP DRAWINGS ARE REQUIRED. ALL LABOR, MATERIAL AND WORKMANSHIP SHALL BE GUARANTEED FOR A PERIOD OF I YEAR FROM THE DATE OF ACCEPTANCE BY THE TENANT. REPLACE OR REPAIR ALL DEFECTS DURING THE GUARANTEED PERIOD.
- THE ELECTRICAL CONTRACTOR SHALL TERMINATE THE ELECTRICAL CONNECTIONS TO ALL THE EQUIPMENT BY PROVIDING THE NECESSARY MALE/FEMALE CONNECTOR, RECEPTACLE, PLUG, ETC.
- 32 ALL DUPLEX OUTLETS AND SWITCHES SHALL BE 20 AMP., 120 VOLT SPEC GRADE. HUBBELL AND PASS & SEYMOUR AND LEVITON ARE APPROVED
- THE ELECTRICAL CONTRACTOR SHALL NOTIFY AND COORDINATE WITH THE MECHANICAL CONTRACTOR SO THAT NO PIPING, DUCTS, OR OTHER EQUIPMENT SHALL BE INSTALLED IN ENTRY OR PASS THROUGH ELECTRICAL ROOM OR SPACES ABOVE OR BELOW ELECTRICAL PANELS.
- ELECTRICAL CONTRACTOR SHALL VERIFY ALL ELECTRICAL LOADS (VOLTAGE, PHASE, CONNECTION REQUIREMENT, ETC.) OF EQUIPMENT FURNISHED UNDER OTHER DIVISIONS WITH APPROVED SHOP DRAWINGS PRIOR TO BEGINNING ROUGH-IN.
- THE CONTRACTOR SHALL INFORM THE ARCHITECT/ENGINEER IN WRITING OF ANY DISCREPANCIES FOUND BETWEEN THE INTENDED FUNCTION OF EQUIPMENT AND EQUIPMENT SPECIFIED IN THE CONTRACT DOCUMENTS A MINIMUM OF TEN (IO) WORKING DAYS PRIOR TO ISSUANCE OF THE FINAL BID. FAILURE TO REPORT ANY DISCREPANCY (CATALOG NUMBERS, DISCONTINUED ITEMS, ETC.) DOES NOT RELIEVE THE CONTRACTOR FROM PROVIDING EQUIPMENT WHICH SHALL CONFORM TO AND FULFILL THE INTENT OF THE CONTRACT DOCUMENTS. NOR SHALL IT BE USED AS A CONDITION TO OBTAIN ADDITIONAL FUNDS FROM THE OWNER AFTER THE CONTRACT IS AWARDED. THE CONTRACTOR SHALL REQUEST ALL CLARIFICATIONS OF CONTRACT DOCUMENT REQUIREMENTS IN WRITING TO THE ARCHITECT/ENGINEER A MINIMUM OF TEN (IO) WORKING DAYS
- PRIOR TO ISSUANCE OF THE FINAL ADDENDUM.

  30 PROVIDE TYPED LABEL FOR ALL DUPLEX OUTLETS AND LIGHT SWITCHES TO
- INDICATE WHICH CIRCUIT THEY ARE TIED TO.

  (3) INSTALL EXIT SIGNS ON THE WALL IF POSSIBLE.
- CONTRACT DOCUMENTS SHALL TAKE PRECEDENCE OVER SHOP DRAWINGS UNLESS SPECIFICALLY NOTED OTHERWISE.
- TO MINIMIZE NUMBER OF FALSE FIRE ALARM DURING CONSTRUCTION, THE CONTRACTOR SHALL CAP SMOKE DETECTORS IN AREAS ADJACENT TO WORK SITE WHILE DUST-GENERATING WORK IS PERFORMED. THESE CAPS SHALL BE REMOVED AT END OF WORKDAY. COORDINATE THE EXTENT OF DEVICE CAPPING REQUIRED WITH CAMPUS FIRE MARSHALL. A LOG SHALL BE KEPT SHOWING THAT ALL CAPS ARE REMOVED AND ACCOUNTED FOR.
- IF, FOR ANY REASON FIRE ALARM SYSTEM CANNOT BE RETURNED TO SERVICE AT THE END OF WORK DAY THE CAMPUS FIRE MARSHALL MUST BE NOTIFIED. CONTRACTOR SHALL PROVIDE FIRE WATCH AT NO ADDITIONAL COST TO THE



## **HFS**Architects

INTERIORS
PLANNING

**A**ARCHITECTURI

1484 South State Street Salt Lake City, Utah 84115 801-596-0691/F: 596-0693 www.hfsa.com

CONSULTANT



E.C.E. INC. 939 So. West Temple Salt Lake City, Utah 84101 Telephone (801) 521-8007

Telefax (801) 521-8057

MARK DATE DESCRIPTION

DATE:

AGENCY PROJECT NO:

HFSA PROJECT NO:

CAD DWG FILE NO:

DRAWN BY:

CHECKED BY:

DESIGNED BY:

DWG TYPE:


ARCHITECTURAL PHASE:

SYMBOLS LIST & GENERAL NOTES

DETAILS, SCHEDULES,


EE001
SHEET 13 OF 17

3



#### REFERENCE NOTES:

- EXISTING DEVICES AND LIGHT FIXTURES SHALL REMAIN. MAKE ANY MODIFICATIONS AS REQUIRED TO MAINTAIN CIRCUIT INTEGRITY.
- RELOCATE THE EXISTING LIGHT FIXTURES TO THE APPROXIMATE LOCATION SHOWN ON ELIOI. REMOVE ASSOCIATED LIGHT SWITCHES, J-BOXES, CONDUIT, CONDUCTORS, ETC. ALL THE WAY BACK TO THEIR ORIGINATION POINTS. REUSE CONDUIT AS POSSIBLE. REMOVE ANY ABANDONED CONDUIT.
- RELOCATE THE EXISTING SMOKE DETECTORS TO THE NEW LOCATIONS SHOWN ON SHEET EPIOI. TRACE CIRCUITS BACK TO NEAREST DEVICE THAT IS TO REMAIN AND FROM THERE EXTEND TO NEW LOCATION.
- REMOVE THE EXISTING DUPLEX WIRE MOLD, VOICE OUTLETS
  AND SPECIAL OUTLETS. REMOVE THEIR ASSOCIATED CONDUIT
  AND CONDUCTORS ALL THE WAY BACK TO ORIGINATION
  POINTS
- REPLACE THE EXISTING FLUSH MOUNTED OUTLETS AND COVER PLATES. EXTEND EXISTING CIRCUITS TO NEW DEVICE.
- FURNISH AND INSTALL NEW 400 AMP CIRCUIT BREAKER SWITCH IN THE APPROXIMATE LOCATION SHOWN. TAP ON TO THE EXISTING 400 AMP FEEDERS AT EXISTING PANEL "A". TIE THE NEW PANELS "DI" & "D2" TO THE NEW 400 AMP CIRCUIT BREAKER. PROVIDE CONDUIT, CONDUCTORS, PULL BOXES, ETC. FOR A COMPLETE INSTALLATION. REFER TO THE PARTIAL POWER SINGLE LINE DIAGRAM FOR MORE INFORMATION.
- REMOVE THE EXISTING EXIT SIGNS. REMOVE ASSOCIATED CONDUCTORS ALL THE WAY BACK TO ORIGINATION POINTS. REUSE CONDUIT AS POSSIBLE. REMOVE ANY ABANDONED CONDUIT AND J-BOXES.



## **HFS**Architects

AARCHITECTURE
INTERIORS
PLANNING

1484 South State Street Salt Lake City, Utah 84115 801-596-0691/F: 596-0693 www.hfsa.com

CONSULTANT



**ELECTRICAL CONSULTING ENGINEERS** 

E.C.E. INC. 939 So. West Temple Salt Lake City, Utah 84101 Telephone (801) 521-8007 Telefax (801) 521-8057

MARK DATE DESCRIPTION

DATE:

AGENCY PROJECT NO:

HFSA PROJECT NO:

CAD DWG FILE NO:

DRAWN BY:

CHECKED BY:

DESIGNED BY:

DWG TYPE:

ARCHITECTURAL PHASE:


MAIN FLOOR DEMOLITION PLAN ELECTRICAL

SHEET TITLE

SHEET

ED101

(4) (B) (II) 4#5*00* MCM I#3 THHN *G*ND /-5 #6 THHN I" CONDUIT 3-1/2" CONDUIT-EQUIPMENT - 4#500 MCM 1#3 THHN GND 3-1/2" CONDUIT SCHEDULE NEW PANEL PANEL "D2" | 120/208V. 3¢, 4W. 400A EXISTING PANEL "A" EXISTING PANEL "B" I20/208V. 3¢, 4W. PANEL "C" 120/208V. 3¢, 4W. 120/208V. 3¢, 4W. 400A TRANSFORMERS I#3 THHN GND ─ # 1/6 AWG GND TO BUILDING STEEL AND MAIN WATER LINE AHEAD OF MAIN VALVE 3-1/2" CONDUIT TO FACILITIES BLDG PAD MOUNTED TRANSFORMER ∽PROVIDE NEW SPLICE BOX AS REQUIRED. - EXISTING SCALE: N.T.S. PARTIAL POWER SINGLE LINE DIAGRAM




REFERENCE NOTES:

EXISTING DEVICES AND LIGHT FIXTURES SHALL REMAIN. MAKE ANY MODIFICATIONS AS REQUIRED TO MAINTAIN CIRCUIT INTEGRITY.

② EXISTING CABLE TRAY TO REMAIN.

SEXISTING HEATER SHALL BE RELOCATED BY MECHANICAL CONTRACTOR. DISCONNECT POWER AND EXTEND ASSOCIATED CONDUIT, CONDUCTORS, ETC. TO THE NEW LOCATION AS SHOWN ON SHEET EPIO2. COORDINATE THIS WORK WITH MECHANICAL CONTRACTOR.



## **HFS**Architects

AARCHITECTURE
INTERIORS
PLANNING

1484 South State Street Salt Lake City, Utah 84115 801-596-0691/F: 596-0693 www.hfsa.com

CONSULTANT



ELECTRICAL CONSULTING ENGINEERS

E.C.E. INC. 939 So. West Temple Salt Lake City, Utah 84101 Telephone (801) 521-8007 Telefax (801) 521-8057

MARK DATE DESCRIPTION

DATE:

AGENCY PROJECT NO: HFSA PROJECT NO:

CAD DWG FILE NO: DRAWN BY:

CHECKED BY:
DESIGNED BY:
DWG TYPE:

DWG TYPE:
ARCHITECTURAL PHASE:

SHEET TITLE


UPPER FLOOR
DEMOLITION PLAN
ELECTRICAL

ED102
SHEET 15 OF 17

UF SCA


<u>UPPER FLOOR DEMOLITION PLAN - ELECTRICAL</u>

SCALE: 1/8" = 1'-0"



#### REFERENCE NOTES:

- EMERGENCY LIGHT FIXTURE INDICATED WITH LETTER "E" SHALL BE PROVIDED WITH A 90 MINUTE BATTERY BACK UP TIED TO CENTER LAMP AND SHALL PROVIDE 1100 LUMENS. PROVIDE UNSWITCHED LIGHTING CIRCUIT TO THE BATTERY PACK TO TURN ON CENTER LAMP UPON COMMERCIAL POWER FAILURE.
- FURNISH AND INSTALL NEW EXIT SIGNS IN THE APPROXIMATE LOCATION SHOWN. TIE TO UNSWITCHED LIGHTING CIRCUIT.
- INSTALL THE EXISTING LIGHT FIXTURES IN THE APPROXIMATE LOCATION SHOWN. TIE TO THE CIRCUIT INDICATED THROUGH NEW LIGHT SWITCHES. PROVIDE NEW LAMPS IN THE RELOCATED FIXTURES. PROVIDE NEW CHAIN HANG KITS AS REQUIRED.



## **HFS**Architects

AARCHITECTURE
INTERIORS
PLANNING

1484 South State Street Salt Lake City, Utah 84115 801-596-0691/F: 596-0693 www.hfsa.com

CONSULTANT



ELECTRICAL CONSULTING ENGINEERS

E.C.E. INC. 939 So. West Temple Salt Lake City, Utah 84101 Telephone (801) 521-8007 Telefax (801) 521-8057

MARK	DATE	DESCRIPTION
DATE:		
AGENCY I	PROJECT NO:	
HFSA PRO	DJECT NO:	
	FILE NO:	

DRAWN BY:
CHECKED BY:
DESIGNED BY:


DESIGNED BY:
DWG TYPE:
ARCHITECTURAL PHASE:

SHEET TITLE

PARTIAL MAIN FLOOR
PLAN LIGHTING

EL101

SHEET 16 OF **17** 



AMPS NQOD, 3-PHASE, 4W

EQUIP #3 CONVEYOR EQUIP #9 LIGHT TABLE

EQUIP. #10 IR 110

EQUIP. #11 ROSSBACK EQUIP #12 SHRINKWRAP

EQUIP #13 BOOK STITCH

EQUIP #14 HOLE DRILL

800 PRINT SHOP C.O.

400 PRINT SHOP C.O.

1000 PRINT SHOP C.O. 800 HIGH VOLUME C.O. SPARE

YES FOR PANEL "D2"

120 208 VOLTS RECESSED

RATING

191.5 A 22.98

C 182.1 C 21.86 186.2 TOTAL 67.09

400 AMPS

PHASE / WIRE

MAIN BREAKER

5 EQUIP. #1 CUTTER

11 EQUIP. #2 FOLDER

7 EQUIP. #4 DPM

21 EQUIP. #5 LETTERPRESS

27 EQUIP. #6 OLIVER

37 EQUIP #8 HYDELBERG 39 PRINT SHOP C.O. 41 PRINT SHOP C.O.

#### REFERENCE NOTES:

- EXISTING DEVICES AND LIGHT FIXTURES SHALL REMAIN. MAKE ANY MODIFICATIONS AS REQUIRED TO MAINTAIN CIRCUIT INTEGRITY.
- INSTALL EXISTING SMOKE DETECTORS IN THE APPROXIMATE LOCATION SHOWN IN THE CEILING. EXTEND EXISTING CONDUIT AND CONDUCTORS TO THE NEW LOCATION FOR A COMPLETE INSTALLATION. COORDINATE EXACT LOCATIONS WITH DUCTWORK AND LIGHT FIXTURES. DO NOT SPLICE THE CONDUCTORS BETWEEN FIRE ALARM DEVICES.
- FURNISH AND INSTALL NEW HORN/STROBES IN THE APPROXIMATE LOCATION SHOWN. TIE TO THE EXISTING FIRE ALARM SYSTEM. PROVIDE ADDITIONAL POWER SUPPLIES, CONDUIT, CONDUCTORS, ETC. AS REQUIRED FOR A COMPLETE INSTALLATION.
- FURNISH AND INSTALL A 4" SQUARE X 2-1/8" J-BOX WITH SINGLE GANG MUD RING IN THE APPROXIMATE LOCATION SHOWN FOR VOICE/DATA OUTLET. RUN A I" CONDUIT FROM J-BOX TO THE NEAREST EXISTING CABLE TRAY. INSERT A PULL STRING AND LABEL CONDUIT AT CABLE TRAY WITH DEVICE LOCATION. DO NOT EXCEED MORE THAN (2)90° BENDS BETWEEN PULL BOXES.
- FURNISH AND INSTALL NEW PANELBOARDS IN THE APPROXIMATE LOCATION SHOWN. REFER TO THE PARTIAL POWER SINGLE LINE DIAGRAM ON SHEET EDIOI FOR MORE INFORMATION.
- INSTALL EXISTING BUCK/BOOST TRANSFORMER ON THE WALL IN THE APPROXIMATE LOCATIONS SHOWN. RUN CIRCUITS FROM EQUIPMENT #8 & #II THROUGH THE NEW TRANSFORMERS. EXISTING TRANSFORMERS ARE LOCATED IN WSU BUILDING NO. 2. COORDINATE WITH OWNER FOR REMOVAL OF TRANSFORMERS. CONTRACTOR SHALL DISCONNECT POWER FROM TRANSFORMER AND REMOVE FROM BUILDING.
- FURNISH AND INSTALL NEW 5 KVA BUCK/BOOST 208/240V
  TRANSFORMERS ON THE WALL IN THE APPROXIMATE
  LOCATIONS SHOWN. RUN CIRCUIT FOR EQUIPMENT #4 THROUGH
  THE NEW TRANSFORMER.
- FURNISH AND INSTALL NEW ALUMINUM POWER POLE IN THE APPROXIMATE LOCATION SHOWN (WIRE MOLD #AMDTP OR APPROVED EQUAL) WITH (2) DUPLEX RECEPTACLES AND FLEXIBLE WHIPS TO FEED EQUIPMENT #7 & #8. PROVIDE PROPER COVER PLATES.
- FURNISH AND INSTALL UNISTRUT SUPPORT FOR NEW STARTER FOR EQUIPMENT #5. RUN CONDUITS FROM CEILING DOWN TO STARTER. REFER TO THE DETAILS FOR MORE INFORMATION. FURNISH NEW EMERGENCY STOP SWITCH ON TOP OF STARTER. TIE TO THE STARTER FOR EMERGENCY DISCONNECT OF EQUIPMENT.
- TIE THE TEMPERATURE CONTROL PANEL TO THE CIRCUIT INDICATED. COORDINATE EXACT LOATION WITH MECHANICAL CONTRACTOR.
- FURNISH AND INSTALL A NEW TVSS IN APPROXIMATE LOCATION SHOWN. TIE TO 60 AMP. CIRCUIT BREAKER IN PANEL DI. REFER TO SPECIFICATION AND POWER SINGLE LINE DIAGRAM FOR MORE INFORMATION.

11		
		2
	A	

## **HFS**Architects

AARCHITECTURE
INTERIORS
PLANNING

1484 South State Street Salt Lake City, Utah 84115 801-596-0691/F: 596-0693 www.hfsa.com

CONSULTANT



ELECTRICAL CONSULTING ENGINEERS

E.C.E. INC.

939 So. West Temple

939 So. West Temple Salt Lake City, Utah 84101 Telephone (801) 521-8007 Telefax (801) 521-8057

DATE:			
AGENCY	PROJECT NO:		
HFSA PR	OJECT NO:		
CAD DWG	FILE NO:		
DRAWN E	BY:		
CHECKE	D BY:		
DESIGNE	D BY:		
DWG TYP	 E:		
ARCHITE	CTURAL PHAS	 BE:	
SHEET TI	 TI F		

DESCRIPTION

MARK

DATE

MAIN FLOOR PLAN
ELECTRICAL


SHEET

EP101
17 OF 17

	PANEL		"D2"					AIC RA	TING	10K		AMPS	NQOD, 3-PHASE, 4W	
	PHASE / WIRE		3/4					RATING	3	120 /	208	VOLTS	RECESSED	
	MAIN LUG		400	AMPS				SUBFE	ED LUG	S		NO		
	MAIN BREAKER			AMPS				COMM	ENT					
CKT	LOCATION	RECEPT	LTG	OTHER	POLE	SIZE	PHASE	SIZE	POLE	OTHER	LTG	RECEPT	LOCATION	CK1
1				3362			Α			16812				2
3				3362			В			16812				4
5	ROOF TOP UNIT RTU-1			3362	3	40	С	175	3	16812			ROOF TOP UNIT RTU-2	6
7	ATC PANEL			300	1	20	Α	20	1				SPARE	8
9	SPARE				1	20	В	20	1				SPARE	10
11	SPARE				1	20	С	20	1				SPARE	12
13	SPARE				1	20	Α	20	1				SPARE	14
15	SPARE				1	20	В	20	1				SPARE	16
17	SPARE				1	20	С	20	1				SPARE	18
19	SALES ROOM C.O.	400			1	20	Α	20	1		1260		PRINT SHOP LTG	20
21	SALES ROOM C.O.	800			1	20	В	20	1		630		PRINT SHOP LTG	22
23	OFFICE C.O.	800			1	20	С	20	1				SPARE	24
25	PRINT LAYOUT C.O.	800			1	20	Α	20	1		1120		PRINT SHOP/HIGH VOL	26
27	PRINT LAYOUT C.O.	200			1	20	В	20	1		900		OFFICE LIGHTING	28
29	SPARE				1	20	С	20	1				SPARE	30
31	SPARE				1	20	Α	20	1				SPARE	32
33	SPARE				1	20	В	20	1				SPARE	34
35	SPARE				1	20	С	20	1				SPARE	36
37	SPARE				1	20	Α	20	1				SPARE	38
39	SPARE				1	20	В	20	1				SPARE	40
41	SPARE				1	20	С	20	1				SPARE	42
		VA	VA	VA		AMPS		KVA		VA	VA	VA		
		1200	0	3662	Α	200.5	Α	24.05	Α	16812	2380	0		
		1000	0	3362	В	189.2	В	22.7	В	16812	1530	0		
		800	0	3362	С	174.8	С	20.97	С	16812	0	0		
		3000	0	10386		188	TOTAL	67.73		50436	3910	0		

				-0 -						
EQUIP. NO.	EQUIPMENT NAME	ELECTRICAL CHARACTERISTIC								
		VOLTS	PHASE	AMP5	HP	KM	WIRE SIZE	CONDUIT SIZE	CONNECTOR TYPE	COMMENTS
	CUTTER	208	3	10.8			3 #12	3/4"	J-BOX	HARDWIRED
2	FOLDER	208	3	21			3 #10	3/4"	J-BOX	HARDWIRED
(3)	PRESS WITH CONVEYOR	120	I	14			2 #12	3/4"	4-PLEX	CORD & PLUG
4	PLATESTREAM DPM	240	I	12.5		3	3 #l2	3/4"	NEMA	CORD & PLUG THROUGH NEW 5KVA BUCK BOOST TRANSFORMERS
(5)	LETTER PRESS HYDELBERG	208	I	9.5			3 #12	3/4"	STARTER	PROVIDE EMERGENCY STOP SWITCH
6	LARGE OLIVER PRESS	208	3	44			3 #6	3/4"	60 A. DISCONNECT	60 AMP FUSES
7	ROYBI PRESS	220	ı	8.5			3 #12	3/4"	POWER POLE	HARDWIRED
8	HYDELBERG PRESS	240	3	13.1		3	3 #12	3/4"	POWER POLE	HARDWIRED, RELOCATE EXISTING (3) 5 KVA BUCK BOOST TRANSFORMERS
$\langle q \rangle$	LIGHT TABLE	120	1	2			2 #12	3/4"	DUPLEX	CORD & PLUG
(10)	IR IIO PRINTER	208	3	24			3 #10	3/4"	NEMA L2I-30	CORD & PLUG
	ROSBACK STITCHER	240	3	12.9			3 <b>#</b> l2	3/4"	NEMA L-14R	CORD & PLUG, RELOCATE EXISTING (3).75 KVA BUCK BOOST TRANSFORMERS
(12)	SRINK WRAPPER	120	ı	15			2 #12	3/4"	DUPLEX	CORD & PLUG
(13)	BOOK STITCHER	120	I				2 #12	3/4"	DUPLEX	CORD & PLUG
(14)	3 HOLE DRILL	208	3	12			3 #12	3/4"	NΕMΔ	CORD & PUIG

EQUIPMENT SCHEDULE




UPPER FLOOR PLAN - ELECTRICAL

SCALE: 1/8" = 1'-0"

#### REFERENCE NOTES:

- EXISTING DEVICES AND LIGHT FIXTURES SHALL REMAIN. MAKE ANY MODIFICATIONS AS REQUIRED TO MAINTAIN CIRCUIT INTEGRITY.
- FURNISH AND INSTALL A NEW DUCT SMOKE DETECTOR WITH SAMPLING TUBE IN THE RETURN AIR DUCT. TIE THE DUCT DETECTOR TO THE NEAREST FIRE ALARM LOOP. IN AND OUT CIRCUITS SHALL BE IN SEPARATE CONDUITS. TIE THE ASSOCIATED AIR HANDLER TO FIRE ALARM SYSTEM FOR AUTOMATIC SHUT DOWN UPON ALARM. PROVIDE CONDUIT, CONDUCTORS, RELAYS, PROGRAMMING, ETC. FOR A COMPLETE INSTALLATION.
- TIE THE OUTLET FURNISHED WITH THE UNIT TO THE CIRCUIT INDICATED.
- $\stackrel{ ext{4}}{ ext{2}}$  INSTALL THREE (3) OF THE LIGHT FIXTURES REMOVED FROM THE FIRST FLOOR IN THE APPROXIMATE LOCATIONS SHOWN.
  TIE TO THE CIRCUIT FEEDING EXISTING LIGHT FIXTURE SHOWN.
  PROVIDE CONDUIT, CONDUCTORS, HANGERS, ETC. FOR A
  COMPLETE INSTALLATION.
- NEW LOCATION OF EXISTING UNIT HEATER. EXTEND EXISTING CONDUIT, J-BOX, THERMAL SWITCH AND CONDUCTORS TO THE NEW LOCATION FOR A COMPLETE INSTALLATION.



## **HFS**Architects

**A**ARCHITECTURE NTERIORS **P**LANNING

1484 South State Street Salt Lake City, Utah 84115 801-596-0691/F: 596-0693 www.hfsa.com

CONSULTANT



ELECTRICAL CONSULTING ENGINEERS

E.C.E. INC. 939 So. West Temple Salt Lake City, Utah 84101 Telephone (801) 521-8007 Telefax (801) 521-8057

MARK	DATE	DESCRIPTION							
DATE:									
AGENCY PROJECT NO:									
HFSA PROJECT NO:									
CAD DWG FILE NO:									
DRAWN BY: JL									
CHECKED BY:									
DESIGNED BY:									
DWG TYPE:									

SHEET TITLE

ARCHITECTURAL PHASE:

UPPER FLOOR PLAN ELECTRICAL

EP102
18 OF 17

SHEET